

SECTION 10: CONSTRUCTION AND REPAIR OF BUILDINGS

10.10: Any new building to be constructed, or any building undergoing additions or renovations equal to twenty percent (20%) of said building's assessed value, must have toilets with a flush volume of one and one-half (1.5) gallons installed or retrofitted to all bathrooms. Any alteration to a bathroom or kitchen must include retrofitting of these devices. [March 13, 1990]